Desert View Power, Inc. an affiliate of

Greenleaf POWER

February 12, 2019

Director, Air Management Division
Attention: A-3-3
U.S. Environmental Protection Agency
75 Hawthorne Street
San Francisco, California 94105-3901

Subject: Desert View Power 2018 Test Plan for Emissions Performance Test

R: A-3-1

NSR 4-4-11

SE 897-01

Dear Sir:

Enclosed is our test plan for the 2019 Emission Performance Testing which is being submitted for your approval. We are planning to conduct testing during the week of March 18, 2019.

If you have any questions, please contact me at (760) 262-1653 direct line or (760) 396-2554 ext 115 general line.

Sincerely,

James Russell Huffman

Vice-President of CA Operations/Plant Manager

62-300 Gene Welmas Dr | Mecca, CA 92254
(760)396-2554
www.greenleafpower.com

U.S. Environmental Protection Agency

Attention: A-3-3

encl.

cc: Air Pollution Control Officer
Attention: Mr. David Jones AQAC Supervisor
SCAQMD FILE #100154
South Coast Air Quality Management District
21865 E. Copley Drive
Diamond Bar, California 91765-4182

Chief, Stationary Source Division
California Air Resources Board
P.O. Box 2815
Sacramento, CA 95814

Air Division, Director, U.S. Environmental Protection Agency
Attn: AIR-5
75 Hawthorne Street
San Francisco, California 94105-3901

TEST PLAN FOR
2019 EMISSIONS PERFORMANCE TESTING AT THE DESERT VIEW POWER PLANT

Prepared For:

Desert View Power
62-300 Gene Welmas Dr.
Mecca, California 92254-0758

For Submittal To:

South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, California 91765-4178

Prepared By:

Montrose Air Quality Services, LLC
1631 E. St. Andrew PL.
Santa Ana, California 92705
(714) 279-6777

Dave Wonderly

Production Date: **February 12, 2019**
Document Number: **002AS-541589-PP-169**

STAC

ACCREDITED
TO ASTM D7036 ONLY
CERT #1993.01

MONTROSE
AIR QUALITY SERVICES

CONFIDENTIALITY STATEMENT

Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.

REVIEW AND CERTIFICATION

I certify that, to the best of my knowledge, the information contained in this document is complete and accurate and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature: _____ Date: 2/12/2019

Name: Dave Wonderly Title: Client Project Manager

I have reviewed, technically and editorially, details and other appropriate written materials contained herein. I hereby certify that to the best of my knowledge the presented material is authentic and accurate and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature: _____ Date: 2/12/2019

Name: Matt McCune Title: Regional Vice President

TABLE OF CONTENTS

LIST OF TABLES

LIST OF FIGURES

1.0 INTRODUCTION

Montrose Air Quality Services, LLC (MAQS) has been contracted by Desert View Power to conduct annual emissions compliance testing on two Fluid Bed Boilers, and a relative accuracy test audit (RATA) of the continuous emissions monitoring system (CEMS) at the Desert View Power Plant located in Mecca, California. MAQS will conduct testing to comply with U.S. Environmental Protection Agency Operating Permit NSR 4-4-11;SE 87-01 including amendments through August 14, 2003: 7th Amendment Title V permit to operate CB-OP 99-01 dated 8/1/2000 and 40 CFR 60, Appendix F. This test plan presents the testing procedures, a description of the sample locations and a summary of quality assurance procedures.

David Wonderly will coordinate the testing for MAQS and can be reached at (714) 279-6777. The on-site test team will consist of a Project Manager whose responsibilities include interfacing with facility personnel, operating the mobile emission measurement laboratory, and performing data entry as well as Technician(s) responsible for all stack responsibilities. A Qualified Individual, as defined in ASTM D7036-04, will be on-site for all methods performed.

Emissions tests will be performed on each Biomass fired boiler as specified in the permit for:

- Particulate
- NO_x, CO and SO_2
- Hydrocarbons
- Hydrogen Chloride (HCl)
- Method 19 F-Factor Using ASTM D6323 and ASTM E711 for Fuel BTU/lb
- Volumetric Flow Rate
- Oxygen and Carbon Dioxide concentration
- Flue gas moisture content

A relative accuracy test audit will be performed to satisfy the requirements of 40 CFR 60, Appendix F, as part of the quarterly CEMS testing. The Continuous Emissions Monitoring System (CEMS) Relative Accuracy Test Audit includes NO_x, CO and SO_2.

2.0 UNIT DESCRIPTION

The Desert View Power Plant consists of two 297 MMBtu/hour, circulating bed, biomass-fired boilers, and combined unit are designed to produce 47 MW of net electrical output. Each unit is equipped with the following pollution control systems:

- An ammonia injection system for control of NO_x emissions;
- Cyclonic mixing of injected ammonia with flue gas to provide for a minimum amount of ammonia slip (emission);
- A limestone injection system to limit emissions of SO_2;
- A hydrated lime injection system to limit emissions of HCL;
- A reverse air baghouse to restrict opacity and emissions of sulfates and particulate to very low levels.

The plant CEM system for each unit includes measurements of NO_x, CO, O_2, O_2 wet, SO_2, CO_2, flow and opacity. It is an extractive system with a heated line extending from the probe to the CEM unit. Table 2-1 presents the current CEMS configuration.

TABLE 2-1
CONTINUOUS EMISSION MONITOR SYSTEM
DESERT VIEW POWER PLANT

Species	Manufacturer	Model	Range
NO_x	CAI	ZRE-5 Multi Component Analyzer	100 and 500 ppm
CO	CAI	ZRE-5 Multi Component Analyzer	100 and 500 ppm
O_2 Dry	CAI	ZRE-5 Multi Component Analyzer	25%
SO_2	CAI	ZRE-5 Multi Component Analyzer	50 and 500 ppm
CO_2	CAI	ZRE-5 Multi Component Analyzer	20%
O_2 Wet	AMETEK	Thermox 2000	25%
Flow	Diet Greg Standard	--	Msdcfh
Opacity	Monitor Labs	Lighthawk 560	100%

2.1 SAMPLE LOCATIONS

Samples will be collected from the transition ducts to the stack. Camot Technical Services, Inc. conducted three dimensional flow testing and stratification testing on the transition exhaust ducts on each unit. This testing was conducted in accordance to SCAQMD chapter X section 1 and 13 and will be presented in the report titled "Stack Gas Stratification and Absence of Flow Disturbance Testing at Desert View Power Mecca Project" (R106E622.T) submitted to SCAQMD in October of 1994. The sample locations met all the requirements. Copies of the results from that report can be found in Appendix B .All testing for both Unit 1 and 2 will be done at the sample location presented in Figure 2-1.

FIGURE 2-1
DESERT VIEW POWER SAMPLE LOCATION



2.2 UNIT OPERATION

The tests will be conducted at or near maximum steady state unit load conditions. Limestone injection rate, fuel combustion rate, ammonia injection rate, ash handling operations, excess air level, combustion air distribution, and combustion temperature will all be set to maintain stable unit operation. Pertinent operating conditions will be recorded by Desert View Power personnel during the tests. Full load will be defined as greater than 267 MMBtu/hr of total (biomass and natural gas) heat input to the boiler.

3.0 TEST PROCEDURES

The test procedures to be used are listed in Table 3-1. Part of the gaseous plant emissions performance testing data will be used for CEMS RATA determinations. A minimum of nine reference method tests are required for all gaseous species relative accuracy (RA) determinations.

TABLE 3-1
PROPOSED TEST MATRIX PER UNIT
DESERT VIEW POWER MECCA PROJECT

Parameter	No. of Tests	Measurement Principle	Reference Method	Duration per Test
NO_x	9(1)	Chemiluminescence	EPA 7E	60/30 minutes
CO	9(1)	Non-Dispersive Infrared	EPA 10	60/30 minutes
O_2/CO_2	9(1)	Non-Dispersive Infrared	EPA 3A	60/30 minutes
PM	3	Gravimetric	EPA 5	90 minutes
SO_2	9(1)	Barium Thorin Titration	EPA 6	60/30 minutes
Hydrocarbons	2	GC/FID	SCAQMD 25.3	60 minute composite
HCL	3	Ion Chromatography	EPA 26A	120 minutes, minimum of 2 DSCM of sample volume
Fuel Sampling	Daily		ASTM D6323	Composite hourly samples
Fuel Btu/lb	Daily		ASTM E711	Composite hourly samples
Fuel Moisture	Daily		ASTM D3173	Composite hourly samples
Fuel Chlorine	Daily		ASTM E776	Composite hourly samples
Stack Gas Flow Rate	--	S-Type Pitot Traverse	EPA 2	--
Moisture	--	Condensation/Gravimetric	EPA 4	--

(1) Includes compliance and RATA test runs.

3.1 CONTINUOUS GASEOUS MEASUREMENTS

NO_x, O_2, CO_2 and CO will be measured according to EPA reference methods using MAQS continuous emissions monitoring system (CEM). NO_x, O_2, CO_2 and CO concentrations will be determined using MAQS mobile emission measurement laboratory. The laboratory is housed in an 18 foot trailer outfitted to provide a clean, quiet, environmentally controlled base for the testing operations. The laboratory has lighting, electrical distribution, air conditioning and heating to support the test instruments and provide for optimal test performance.

Concentrations of these gaseous species are measured using an extractive sampling system consisting of a heated stainless steel probe to minimize reactions, a heat traced Teflon sample line connected to a thermo-electrically cooled sample dryer. Following the dryer, the sample is drawn into a Teflon lined pump where it is pressurized and then filtered for delivery to the gas analysis portion of the system. Gaseous samples will be collected at a single point. Three minimum 60-minute compliance tests will be performed.

NO_x concentration is determined using a California Analytical Instruments (CAI) chemiluminescence analyzer (model 600 Series). The analyzer has full scale ranges from 2.5 to 10,000 ppm. The analyzer is equipped with a vitreous carbon NO_2 - NO converter for the determination of total nitrogen oxides without interference from other nitrogen containing compounds.

Oxygen concentration is determined using a AMI electro-chemical cell analyzer (model # 201). The analyzer has three full scale ranges; 0-5%, 10%, and 25%. The cell contains an electrolytic fluid that reacts with oxygen to generate an electrical signal proportional to the concentration.

CO_2 is measured using a non-dispersive infrared analyzer manufactured by CAI (model # 100 Series). The analyzer has full scale ranges of 0-5%, 10%, 20% and 40%.

CO is measured using a non-dispersive infrared/gas filter correlation analyzer manufactured by TECO (model # 48i). The analyzer has user definable full scale ranges from of 0-10 to 0-10,000 ppm.

The analyzers and sampling system are subjected to a variety of calibration and quality assurance procedures including leak checks, linearity and calibration error determinations before sampling, and system bias and drift determinations as part of each test run. Data are corrected for any observed bias or drift in accordance with the reference methods.

3.2 PARTICULATE MEASUREMENTS

EPA method 5 sampling system will be used to measure the particulate emissions from both Desert View Power units. The sampling system consists of a nozzle, glass probe, 250°F heated filter, two impingers containing DI water, a third empty impinger and a fourth impinger containing silica gel.

The analysis for particulate is summarized in Table 3-2. Gravimetric Analysis will be performed on the probe/nozzle wash and filter.

TABLE 3-2
EPA METHOD 5 ANALYSES

Sample Component	Analysis Procedure
Probe and Nozzle (Front 1/2)	Evaporation/gravimetric
Heated Filter (83 mm)	Bake/gravimetric

3.3 SULFUR DIOXIDE

Sulfur dioxide will be measured according to EPA Method 6. The first three runs will be 60 minutes and will be used to demonstrate compliance and as RATA runs. Subsequent RATA runs will consist of 30 minute tests per the Methods. A barium thorin titration of the hydrogen peroxide impinger samples will yield SO_2 concentrations for nine relative accuracy test runs. The sample system will consist of a heated glass probe connected to the impinger train with an un-heated Teflon sample line. All the unheated portion of the sample train will be recovered and analyzed. Prior to the titrimetric analysis, all SO_x samples will pass through an ion exchange resin. This removes interference associated with ammonium (NH_4^+). The Method 6 train will not include the IPA impinger, which is provided in the method as an option. The H_2O_2 will absorb both SO_2 and SO_3 (if any). SO_3 will be counted as SO_2.

3.4 HYDROCARBON

Samples for hydrocarbon analysis will be collected in clean 6-L Summa Canister and mini water impingers and analyzed according to SCAQMD 25.3. The samples will be analyzed by AtmAA Inc. in Calabasas, CA using TCA/FID or other qualified laboratory. Results will be reported as total non-methane hydrocarbons as carbon.

3.5 HYDROGEN CHLORIDE MEASUREMENTS

Triplicate hydrogen chloride (HCl), samples will be collected using EPA Method 26A. Sampling and analysis for HF and Cl2 which is included in EPA Method 26A will not be performed. The sampling train consists of:

- A glass nozzle and heated glass probe heated to between 248°F and 273°F
- A Teflon Mat or quartz out-of-stack filter in a glass filter holder heated to 248°F ± 25°F
- Two impingers containing 100 ml of 0.1 N H_2SO_4 for collection of HCl
- One empty impinger
- An impinger containing silica gel

Samples are withdrawn isokinetically from the stack. The Teflon Mat or quartz-fiber filter collects particulate matter. The acidic absorbing solution collect gaseous HCl and is analyzed for HCl by ion chromatography.

The samples are recovered in the following sample fractions:

1. Back half of filter holder, H_2SO_4 Impinger Catch – Weighed for moisture content and recovered with DI water into pre-cleaned HDPE bottle.
2. The filter and probe wash will not be recovered for this test program.

Quality assurance samples collected in the field are:

- A field blank
- A reagent blank: 200 ml of 0.1 N H_2SO_4
- A reagent blank: 200 ml of DI water

The samples will be analyzed by ion chromatography by AAC in Ventura or other qualified laboratory.

3.6 VELOCITY AND MOISTURE

Stack gas velocity and moisture content will be determined by EPA Methods 2 and 4 during the particulate test. Velocity traverses will be performed during each set of compliance tests (NO_x, CO, SO_2 and hydrocarbons) and for each RATA run.

3.7 FUEL ANALYSIS

Daily fuel samples will be collected by Desert View Power personnel. Hourly samples will be taken and composited by the lab prior to analysis. Sampling will be consistent with ASTM D6323 sample collection methodology. MAQS will send the samples out to be analyzed for higher heating value for heat rate calculations, for Btu/lb for calculating the HCL emissions in lb/MMBtu using ASTM E711, for moisture content using ASTM D3173 and for chlorine content using ASTM E776. Copies of the analysis will be included with the final report.

3.8 RELATIVE ACCURACY TEST AUDIT

Relative Accuracy tests will be performed for NO_x, SO_2, CO and O_2 on sub systems of each unit's CEMS. Relative accuracy is determined by comparing the CEMS data to the corresponding reference method (RM) data over nine to twelve test runs. Nine 30-minute minimum tests will be performed for the NO_x, SO_2, CO, and O_2 relative accuracy. Relative accuracy is expressed in terms of the absolute value of the mean of the difference between the monitor value and the reference method value. It is reported in terms of a percentage of the mean reference method value. The computational procedure is summarized by the following equations:

$$\overline{RM} = \frac{1}{n} \sum_{i=1}^{n} RM_1$$

$$\bar{d} = \sum_{i=1}^{n} d_i$$

$$S_d = \left[\frac{\sum_{i=1}^{n} d_i^2 - \frac{\left(\sum_{i=1}^{n} d_i\right)^2}{n}}{n-1} \right]^{\frac{1}{2}}$$

$$CC = t_{0.975} \frac{S_d}{\sqrt{n}} 1$$

$$RA = \frac{|\bar{d}| + |cc|}{\overline{RM}} x100$$

The RA will be determined for the monitoring systems in parts per million dry (ppm) and lb/hr.

3.9 TEST SCHEDULE

The scheduled test dates have been set for March 19 – March 22, 2019 for compliance and RATA testing. A proposed test schedule for on-site testing activities is shown in Table 3-3. This schedule is based on the number of tests and the required sample times.

Date	Unit No.	Test No.	Type of Test
3/18/2019	1	--	Set-up
3/19/2019	1	1-3 PM, 1-3 HCL 1-3 Comp RATA testing	Particulate Tests 1-3, HCL Tests 1-3 CEMS RATA and Compliance NO_x, SO_2, CO &VOC Tests 1-3 Fuel Samples
3/20/2019	1	RATA testing Continued	CEMS RATA
3/21/2019	2	1-3 PM, 1-3 HCL 1-3 Comp RATA testing	Particulate Tests 1-3, HCL Tests 1-3 CEMS RATA and Compliance NO_x, SO_2, CO &VOC Tests 1-3 Fuel Samples
3/22/2019	2	RATA testing Continued	CEMS RATA

4.0 REPORTING

MAQS will prepare a comprehensive emissions report that includes all raw data and calculations for the test program. The test format is presented in Table 4-1. The test report will be submitted within 45 days from completion of testing.

TABLE 4-1
REPORT FORMAT

Title page
Report Title
Prepared For
For Submittal To:
Author and reviewer names
Test Dates and Report Issue Date
Report Number

Review Page
Signatures of person who prepared the report and signature of person who reviewed the report

Table of Contents

Introduction and Summary
Identifies the client, source, reason for the test, test date(s), test personnel, client/source personnel, regulatory observers
Summarizes the results of the test, indicates applicable rules and pass/fail criteria and makes a statement regarding the test results
Outlines the organization of remainder of the report.
Table of analysis results

Unit Description
Describes the process which was tested
Describes any applicable control equipment
Test conditions

Test Description
Test methods, replicates, duration, calculations
Test locations
Test critique

Results
Re-states the results of the test and makes a statement regarding compliance with applicable regulations
Results tables with more detail on individual test runs and supporting data

Appendices
A. Test and Laboratory Data
   1. Test Location
   2. Test Data (by type)
   3. Quality Assurance Data
      a. Certification
      b. Equipment Calibration
      c. Calibration Gas Certificate
      d. Chain of Custody
B. Process Operating Data
C. Measurement Procedures
D. Calculations
E. Instrument Strip Charts

APPENDIX A
QUALITY ASSURANCE AND CERTIFICATIONS

QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (MAQS) ASTM D7036-04 certification, MAQS is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. MAQS quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: MAQS has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: MAQS has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of MAQS QA efforts. The manual is revised upon periodic review and as MAQS adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. MAQS training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the MAQS QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of MAQS emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: MAQS maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: MAQS maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to MAQS source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to MAQS office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

ASTM D7036-04 Required Information

Uncertainty Statement

"Both qualitative and quantitative factors contribute to field measurement uncertainty and should be taken into consideration when interpreting the results contained within this report. Whenever possible, Montrose Air Quality Services, LLC (MAQS) personnel reduce the impact of these uncertainty factors through the use of approved and validated test methods. In addition, MAQS personnel perform routine instrument and equipment calibrations and ensure that the calibration standards, instruments, and equipment used during test events meet, at a minimum, test method specifications as well as the specifications of our Quality Manual and ASTM D 7036-04. The limitations of the various methods, instruments, equipment, and materials utilized during this test have been reasonably considered, but the ultimate impact of the cumulative uncertainty of this project is not fully identified within the results of this report."

Performance Data

Performance data are available for review.

Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, will be present on each test event.

Plant Entry and Safety Requirements

Plant Entry

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

Safety Requirements

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)

The following safety measures will be followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

TABLE 1
EQUIPMENT MAINTENANCE SCHEDULE

Equipment	Acceptance Limits	Frequency of Service	Methods of Service
Pumps	1. Absence of leaks 2. Ability to draw manufacturers required vacuum and flow	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Replace parts 4. Leak check
Flow Meters	1. Free mechanical movement	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero span gas	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobil Van Sampling System	1. Absence of leaks	Depends on nature of use	1. Chang filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry

TABLE 2
MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO_x Analyzer	Daily	NO_2 -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	+/- 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	+/- 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	+/- 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	+/- 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	+/- 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for ΔH@	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	+/- 1.5%

Note: Calibration requirements will be used that meet applicable regulatory agency requirements.

South Coast
Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

October 30, 2018

Mr. John Peterson
Montrose Air Quality Services, LLC
1631 E. Saint Andrew Place
Santa Ana, CA 92705

Subject: LAP Approval Notice
Reference # 96LA1220

Dear Mr. Peterson:

We have reviewed your renewal letter under the South Coast Air Quality Management District's Laboratory Approval Program (SCAQMD LAP). We are pleased to inform you that your firm is approved for the period beginning October 30, 2018, and ending September 30, 2019 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

SCAQMD Methods 1-4	SCAQMD Methods 5.1, 5.2, 5.3, 6.1
SCAQMD Methods 10.1 and 100.1	SCAQMD Methods 25.1 and 25.3 (Sampling)
USEPA CTM-030 and ASTM D6522-00	SCAQMD Rule 1121/ 1146.2 Protocol
SCAQMD Rule 1420/1420.1/1420.2 – (Lead) Source and Ambient Sampling	

Your LAP approval to perform nitrogen oxide emissions compliance testing for SCAQMD Rule 1121/ 1146.2 Protocols includes satellite facilities located at:

McKenna Boiler 1510 North Spring Street Los Angeles, CA 90012	Noritz America Corp. 11160 Grace Avenue Fountain Valley, CA 92708	Ajax Boiler, Inc. 2701 S. Harbor Blvd. Santa Ana, CA 92704

Thank you for participating in the SCAQMD LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at gkasai@aqmd.gov.

Sincerely,

D. Sarkar

Dipankar Sarkar
Program Supervisor
Source Test Engineering

DS:GK/gk

Attachment

181030LapRenewalRev.doc



State of California
Air Resources Board
Approved Independent Contractor

Montrose Air Quality Services, LLC

This is to certify that the company listed above has been approved by the California Air Resources Board to conduct compliance testing pursuant to California Code of Regulations, title 17, section 91207, through June 30, 2020, for those test methods listed below:

CARB Source Test Methods:
1, 2, 3, 4, 5, 6, 8, 17, 20
100 (CO, CO_2, NO_x, O_2, SO_2, THC)

Dr. Michael T. Benjamin, Chief
Monitoring and Laboratory Division



State of California
Air Resources Board
Approved Independent Contractor

Montrose Air Quality Services, LLC

This is to certify that the company listed above has been approved by the California Air Resources Board to conduct compliance testing pursuant to California Code of Regulations, title 17, section 91207, through June 30, 2020, for those test methods listed below:

U.S. EPA Source Test Methods 201A, 202 and 205
Visible Emissions Evaluation

Dr. Michael T. Benjamin, Chief
Monitoring and Laboratory Division

American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 5th day of March 2018.

President and CEO
For the Accreditation Council
Certificate Number 3925.01
Valid to February 29, 2020

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

APPENDIX B
SAMPLE LOCATION VERIFICATION DATA

STACK GAS STRATIFICATION AND ABSENCE OF FLOW DISTURBANCE TESTING AT COLMAC MECCA PROJECT

Prepared For:

UC Operating Service
Mecca, California

For Submittal To:

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
Diamond Bar, California

Prepared By:

Edward J. Filadelfia

CARNOT
Tustin, California

JULY 1994

REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and documented in this report were carried out under my direction and supervision.

Edward J. Filadelfia
Senior Engineer

Date 10/14/94

I have reviewed, technically and editorially, details, calculations, results, conclusions and other appropriate written material contained herein, and bereby certify that the presented material is authentic and accurate.

Edward J. Filadelfia
Senior Engineer

Date 10/14/94

TABLE OF CONTENTS

SECTION 1.0

INTRODUCTION

Carnot was contracted by UC Operating Service (UCOS) to determine the suitability of the alternate sample location accessible from the stack inlet duct. Tests were conducted to determine the level of stack gas stratification and flow disturbance. The tests were performed at this location to satisfy the requirements of alternate sample location CFR 40 Appendix A Method 1. The tests were performed using the standard methods in Chapter X of the SCAQMD's Source Test Manual.

The flow disturbance and gaseous stratification tests were performed on June 27-28, 1994. The test program was coordinated by Greg Deedon of UCOS and Edward Filadelfia of Carnot. The Carnot test team consisted of Edward Filadelfia, Dave Wonderly, and Chris Hone. Unit operation was established and maintained by UCOS personnel.

The results of the tests are summarized in Tables 1-1 and 1-2. These results show that the sample location meets the requirements of the SCAQMD and EPA by demonstrating that the stack gas stratification is less than 10% and the average resultant flow angle is less than 20 degrees with a standard deviation of less than 10 degrees.

A description of the unit is presented in Section 2.0. Test procedures and locations are presented in Section 3.0. Test results are presented in Section 4.0. Tests procedure descriptions, field data sheets, calculations, and control room data are included in the Appendices.

TABLE 1-1
SUMMARY OF GASEOUS STRATIFICATION
COLMAC ENERGY PROJECT
JULY 1994

Parameter	Unit 1 % Stratification	Unit 2 % Stratification	SCAQMD Limit, %
O_2, %	0.4%	1.0%	≤10

TABLE 1-2
SUMMARY OF FLOW DISTURBANCE MEASUREMENTS
COLMAC ENERGY PROJECT
JULY 1994

Parameter	Unit 1 Measured	Unit 2 Measured	SCAQMD Limit, %	EPA Limit, %
Average Resultant Angle, Degrees	5.6°	5.9°	≤20	≤20
Standard Deviation, Degrees	3.3°	4.0°	≤10	N/A

SECTION 2.0

UNIT DESCRIPTION

The Colmac Energy Plant consists of two 297 MMBtu/hour, circulating bed boilers, the combined units are designed to produce 47 MW of net electrical output. Each unit is equipped with the following pollution control systems:

1. An ammonia injection system for control of NO_x emissions.

2. Cyclonic mixing of injected ammonia with flue gas to provide for a minimum amount of ammonia slip (emission).

3. A limestone injection system to limit emissions of SO_2.

4. A reverse air baghouse to restrict opacity and emissions of sulfates and particulate to very low levels.

SECTION 3.0

TEST DESCRIPTION

3.1 TEST CONDITIONS

All tests were performed with the unit operating at full load. Tests were conducted while the unit was firing bio mass and operating under normal conditions. Unit operations were established by UCOS operators.

3.2 SAMPLE LOCATION

Measurements were made from Units 1 and 2 inlet ducts to the stack. A schematic of the Sample location is shown in Figure 3-1. Chapter X sampling consisted of 40 point traverse for stratification, and a 42 point traverse for flow disturbances.

3.3 TEST PROCEDURES

Tests were performed using methods from the SCAQMD's Source Test Manual. These methods are contained in Chapter X - Section 1 for disturbed flow and Section 13 for gaseous stratification. Table 3-1 presents the test methods used in this program. O_2 concentrations were measured using Carnot's mobile emission monitoring system. Flow angles were measured using a United Sensor 3D probe. A description of the Carnot's Continuous Emissions Monitoring System and the standard measurement procedures are presented in Appendix A. A summary of the procedures used for gaseous stratification and disturbed flow are presented below.

3.3.1 Gaseous Stratification

Chapter X (Non-Standard Methods and Techniques), Chapter 13 of the SCAQMD Source Test Manual defines gaseous stratification as the presence of a difference, in excess of 10 percent, between any two points in the same cross sectional plane. Stratification can be determined for either pollutant gases (e.g., NO_x) or diluent gases (e.g., O_2, CO_2) in units of concentration. For this test program, the O_2 concentration was used to measure the level of stack gas stratification.



Figure 3-1. UCOS - Duct Sample Locations

Due to variations in process O_2 concentrations, two O_2 analyzers were used. The first O_2 analyzer was used as a reference point and located at the center of the duct. The second was located at 40 traverse points during the test. Gases were monitored for three minutes at each traverse point.

TABLE 3-1
TEST PROCEDURES
COLMAC ENERGY PROJECT
JULY 1994

Parameter	Units	Measurement Principle	Reference Method	Comments
O_2	%	Electrochemical Call	EPA 3A	40 point traverse for gaseous stratification according to Chapter X, Section 13
Flow Angle	Degrees	3D probe for pitch and yaw	1.1	42 point traverse for disturbed flow according to Chapter X, Section 1

SECTION 4.0

RESULTS

4.1 GASEOUS STRATIFICATION

The results of the gaseous stratification tests are summarized in Table 4-1. The results show that the O_2 concentration stratification levels for both sample locations were below the limit of 10%.

TABLE 4-1
GASEOUS STRATIFICATION
COLMAC ENERGY PROJECT
JULY 1994

Parameter	Percent Stratification
Unit 1 O_2, %	0.4%
Unit 2 O_2, %	1.0%

4.2 FLOW DISTURBANCE

The results of the flow disturbance measurements made with the 3-dimensional velocity probe are presented in Table 4-2. The results of these tests show that the average resultant flow angle was below the limit of 20 degrees with a standard deviation of less than 10 degrees for both sample locations.

TABLE 4-2
FLOW DISTURBANCE RESULTS
COLMAC ENERGY PROJECT
JULY 1994

Parameter	Unit 1 3D Probe	Unit 2 3D Probe
Avg. Yaw Angle, degrees	2.0	4.4
Avg. Pitch Angle, degrees	-0.4	-1.0
Avg. Resultant Angle, degrees	5.6	5.9
Standard Deviation, degrees	3.3	4.0

APPENDIX A
MEASUREMENT PROCEDURES

Continuous Emissions Monitoring System

Oxygen (O_2) by Continuous Analyzer

Three-Dimensional Velocity Testing

Continuous Emissions Monitoring System

O_2, CO, CO_2, NO, NO_x and SO_2 are measured using an extractive continuous emissions monitoring (CEM) package, shown in the following figure. This package is comprised of three basic subsystems. They are: (1) the sample acquisition and conditioning system, (2) the calibration gas system, and (3) the analyzers themselves. This section presents a description of the sampling and calibration systems. Descriptions of the analyzers used in this program and the corresponding reference test methods follow. Information regarding quality assurance information on the system, including calibration routines and system performance data follows.

The sample acquisition and conditioning system contains components to extract a representative sample from the stack or flue, transport the sample to the analyzers, and remove moisture and particulate material from the sample. In addition to performing the tasks above, the system must preserve the measured species and deliver the sample for analysis intact. The sample acquisition system extracts the sample through a stainless steel probe. The probe is insulated or heated as necessary to avoid condensation. If the particulate loading in the stack is high, a sintered stainless steel filter is used on the end of the probe.

Where water soluble NO_2 and/or SO_2 are to be measured, the sample is drawn from the probe through a heated teflon sample line into an on-stack cooled (approximately 35-40°F) water removal trap. The trap consists of stainless steel flasks in a bath of ice and water. This design removes the water vapor by condensation. The contact between the sample and liquid water is minimized and the soluble NO_2 and SO_2 are conserved. This system meets the requirements of EPA Method 20. The sample is then drawn through a teflon transport line, particulate filter, secondary water removal and into the sample pump. The pump is a dual head, diaphragm pump. All sample-wetted components of the pump are stainless steel or teflon. The pressurized sample leaving the pump flows through a third condensate trap in a refrigerated water bath (≈38°F) for final moisture removal. A drain line and valve are provided to constantly expel any condensed moisture from the dryer at this point. After the dryer, the sample is directed into a distribution manifold. Excess sample is vented through a back-pressure regulator, maintaining a constant pressure of 5-6 psig to the analyzer rotameters.

The calibration system is comprised of two parts: the analyzer calibration, and the system bias check (dynamic calibration). The analyzer calibration equipment includes pressurized cylinders of certified span gas. The gases used are, as a minimum, certified to 1% by the manufacturer. Where necessary to comply with reference method requirements EPA Protocol 1 gases are used. The cylinders are equipped with pressure regulators which supply the calibration gas to the analyzers at the same pressure and flow rate as the sample. The selection of zero, span, or sample gas directed to each analyzer is accomplished by operation of the sample/calibration selector fittings.

The system bias check is accomplished by transporting the same gases used to zero and span the analyzers to the sample system as close as practical to the probe inlet. This is done either by attaching the calibration gas supply line to the probe top with flexible tubing or by actuation of a solenoid valve located at the sample conditioner inlet (probe exit). The span gas is exposed to the same elements as the sample and the system response is documented. The analyzer indications for the system calibration check must agree within 5% of the analyzer calibration. Values are adjusted and changes/repairs are made to the system to compensate for any difference in analyzer readings. Specific information on the analytical equipment and test methods used is provided in the following pages.



Schematic of CEM System

Method:	Oxygen (O_2) by Continuous Analyzer
Applicable Reference Methods:	EPA 3A, EPA 20, ARB 100, BA ST-14, SCAQMD 100.1
Principle:	A sample is continuously drawn from the flue gas stream, conditioned, and conveyed to the instrument for direct readout of O_2 concentration.
Analyzer:	Teledyne Model 326A
Measurement Principle:	Electrochemical cell
Ranges:	0-5, 0-10, 0-25 % O_2
Accuracy:	1 % of full scale
Output:	0-100 mV, linear
Interferences:	Halogens and halogenated compounds will cause a positive interference. Acid gases will consume the fuel cell and cause a slow calibration drift.
Response Time:	90% <7 seconds
Sampling Procedure:	A representative flue gas sample is collected and conditioned using the CEM system described previously. If Method 20 is used, that method's specific procedures for selecting sample points are used. Otherwise, stratification checks are performed at the start of a test program to select single or multiple-point sample locations.
Analytical Procedure:	An electrochemical cell is used to measure O_2 concentration. Oxygen in the flue gas diffuses through a Teflon membrane and is reduced on the surface of the cathode. A corresponding oxidation occurs at the anode internally, and an electric current is produced that is proportional to the concentration of oxygen. This current is measured and conditioned by the instrument's electronic circuitry to give an output in percent O_2 by volume.
Special Calibration Procedure:	The measurement cells used with the O_2 instrument have to be replaced on a regular basis. After extended use, the cell tend to produce a nonlinear response. Therefore, a three-point calibration is performed at the start of each test day to check for linearity. If the response is not linear ($\pm$ 2% of scale), the cell is replaced.

Method:	Three-Dimensional Velocity Testing
Applicable Ref. Method:	EPA Method 1, ANSI ASME PTC 11 - 1984
Applicability of Method:	When a sample location to be used for velocity or particulate tests does not meet the traditional Method 1 criteria of being at least two duct diameters downstream and one-half diameter upstream of any flow disturbance, this alternate method is used to evaluate the suitability of the location. A three-dimensional velocity probe is used to measure pitch and yaw angle at a minimum of 40 traverse points for round ducts and 42 points for rectangular ducts. If the average resultant angle is less than 20° and the standard deviation is less than 10°, the sample location is deemed acceptable. Velocity and particulate traverses are then performed at the same traverse points using standard Method 2 and 5 equipment and procedures.
Principle:	The instrument measures yaw and pitch angles of fluid flow, as well as total and static pressures.
Analyzer:	United Sensor Three-Dimensional Directional Probe
Sampling Procedure:	Each probe has five measuring holes in its tip. A centrally located pressure hole measures pressure P1, while two lateral pressure holes measure pressures P2 and P3. If the probe is rotated manually until P2 and P3 are identical as a readout on the manometer, the yaw angle of flow is then indicated by the number of degrees rotated. When the yaw angle has been determined, an additional differential pressure P4 - P5 is measured by pressure holes located above and below the total pressure (P1) hole. Pitch angle is determined by calculating (P4 - P5)/(P1 - P2) and using the calibration data for the individual probe and interpolating between the bracketing data. At any particular pitch angle, the velocity pressure coefficient (Pt - Ps)/(P1 -P2) can also be interpolated from the calibration data and Pt - Ps and Ps calculated. Note that this probe also allows for very accurate gas flow measurements, in addition to the EPA Method 1 procedures that allow it to be used for determination of flow angle.

Definitions:

P_1 = Total Pressure
P_2 = Static Pressure
P_3 = Static Pressure
P_4 = Pitch Pressure
P_5 = Pitch Pressure

$P_1 - P_2$ = Velocity Head Pressure

$\frac{P_4 - P_5}{P_1 - P_2}$ = Pitch angle calculated on calibration curve

Calculations:

Velocity (fps) in direction of flow

$$V_s = 2.90\ C_P \sqrt{\Delta P\ T_s}\ \sqrt{\left(\frac{29.92}{P_S}\right)\left(\frac{28.95}{MW_{wet}}\right)}$$

where:
C_P = Pitot Calibration factor

ΔP = Average velocity, head, iwg $(\overline{\sqrt{\Delta P}})^2$
T_S = Stack Temperature, °R
P_S = Stack Pressure (iwg)
MW_{wet} = Molecular weight, wet

Resultant angle:

$$R = \left| \frac{\cos^{-1}\left(\cos\phi_{Y,R}\ \cos\phi_{P,R}\right)}{0.0175} \right|$$

where:
$\phi_{Y,R}$ = Yaw Angle in Radians
$\phi_{P,R}$ = Pitch Angle in Radians
R = Resultant Angle in Degrees

Pitch Angle Curve Fit Equation (Degrees)

$$\phi_P = A_1\left(\frac{P_4-P_5}{P_1-P_2}\right) + A_2\left(\frac{P_4-P_5}{P_1-P_2}\right)^2 - A_3\left(\frac{P_4-P_5}{P_1-P_2}\right)^3 - A_4\left(\frac{P_4-P_5}{P_1-P_2}\right)^4 + A_5\left(\frac{P_4-P_3}{P_1-P_2}\right)^5 + A_6\left(\frac{P_4-P_5}{P_1-P_2}\right)^6$$

Pitot coefficient curve fit equation (used to calculate corrected axial velocities)

$$\frac{P_t - P_s}{P_1 - P_2} = B_1 + B_2\,\phi_P + B_3 + \phi_P + B_4\,\phi_P^3 + B_5\,\phi_P^4 + B_6\,\phi_P^5 + B_7\,\phi_P^6$$



Figure Five Hole Probe

3-DIMENSIONAL VELOCITY PROBE CALIBRATION FACTORS

Probe	B-2455
A_1	63.09
A_2	23.69
A_3	24.505
A_4	33.312
A_5	7.5203
A_6	11.669
B_1	0.997
B_2	7×10^{-3}
B_3	3×10^{-5}
B_4	8×10^{-7}
B_5	1×10^{-9}
B_6	3×10^{-10}
B_7	3×10^{-2}

APPENDIX B
QUALITY ASSURANCE

Appendix B.1

Quality Assurance Program Summary

QUALITY ASSURANCE PROGRAM SUMMARY AND ARB CERTIFICATION

Carnot ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA Officer and encompasses seven major areas:

1. Development and use of an internal QA manual.
2. QA reviews of reports, laboratory work, and field testing.
3. Equipment calibration and maintenance.
4. Chain of custody.
5. Training.
6. Knowledge of current test methods.
7. Agency certification.

Each of these areas is discussed individually below.

Quality Assurance Manual. Carnot has prepared a QA Manual according to EPA guidelines. The manual serves to document and formalize all of Carnot's QA efforts. The manual is constantly updated, and each member of the Source Test Division is required to read and understand its contents. The manual includes details on the other six QA areas discussed below.

QA Reviews. Carnot's review procedure includes review of each source test report by the QA Officer, and spot check reviews of laboratory and field work.

The most important review is the one that takes place before a test program begins. The QA Officer works closely with Source Test Division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of any interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance. The equipment used to conduct the emissions measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the California Air Resources Board (CARB). The schedule for maintenance and calibrations are given in Tables B-1 and B-2. Quality control checks are also conducted in the field for each test program. The following is a partial list of checks made as part of each CEM system test series.

- Sample acquisition and conditioning system leak check.
- 2-point analyzer calibrations (all analyzers)
- 3-point analyzer calibrations (analyzers with potential for linearity errors).
- Complete system calibration check ("dynamic calibration" through entire sample system).

- Periodic analyzer calibration checks (once per hour) are conducted at the start and end of each test run. Any change between pre- and post-test readings are recorded.

- All calibrations are conducted using gases certified by the manufacturer to be + 1% of label value (NBS traceable).

Calibration and CEM performance data are fully documented, and are included in each source test report.

Chain of Custody. Carnot maintains full chain of custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Carnot documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.).

Samples are stored in a locked area to which only Source Test Division personnel have access. Neither other Carnot employees nor cleaning crews have keys to this area.

Data sheets are copied immediately upon return from the field, and this first generation copy is placed in locked storage. Any notes made on original sheets are initialed and dated.

Training. Personnel training is essential to ensure quality testing. Carnot has formal and informal training programs which include:

1. Attendance at EPA-sponsored training courses.
2. Enrollment in EPA correspondence courses.
3. A requirement for all technicians to read and understand Carnot's QA Manual.
4. In-house training and QA meetings on a regular basis.
5. Maintenance of training records.

Knowledge of Current Test Methods. With the constant updating of standard test methods and the wide variety of emerging test methods, it is essential that any qualified source tester keep abreast of new developments. Carnot subscribes to services which provide updates on EPA and CARB reference methods, and on EPA, CARB and SCAQMD rules and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Carnot personnel maintain membership in the Air and Waste Management Association, the Source Evaluation Society, and the ASME Environmental Control Division.

AGENCY CERTIFICATION

Carnot is certified by the CARB as an independent source test contractor for gaseous and particulate measurements. Carnot is certified by the SCAQMD as an independent source test contractor for gaseous and particulate measurements using SCAQMD Methods 1, 2, 3, 4, 5, 6, 7 and 100.1. Carnot also participates in EPA QA audit programs for Methods 5, 6 and 7.

TABLE B-1
SAMPLING INSTRUMENTS AND EQUIPMENT CALIBRATION SCHEDULE
As Specified by the CARB

Instrument Type	Frequency of Calibration	Standard of Comparison or Method of Calibration	Acceptance Limits
Orifice Meter (large)	12 months	Calibrated dry test meter	± 2% of volume measured
Dry Gas Meter	12 months or when repaired	Calibrated dry test meter	± 2% of volume measured
S-Type Pitot (for use with EPA-type sampling train	6 months	EPA Method 2	Cp constant (+5%) over working range; difference between average Cp for each leg must be less than 2%
Vacuum Gauges Pressure Gauges	6 months	Manometer	± 3%
Field Barometer	6 months	Mercury barometer	± 0.2" Hg
Temperature Measurement	6 months	NBS mercury thermometer or NBS calibrated platinum RTD	± 4°F for <400°F ± 1.5% for >400°F
Temperature Readout Devices	6 months	Precision potentiometer	± 2% full scale reading
Analytical Balance	12 months (check prior to each use)	Should be performed by manufacturer or qualified laboratory	± 0.3 mg of stated weight
Probe Nozzles	12 Months	Nozzle diameter check micrometer	Range < ± 0.10 mm for three measurements
Continuous Analyzers	Depends upon use, frequency and performance	As specified by manufacturers operating manuals, EPA NBS gases and/or reference methods	Satisfy all limits specified in operating specifications

TABLE B-2
EQUIPMENT MAINTENANCE SCHEDULE
Based on Manufacturer's Specifications and Carnot Experience

Equipment	Performance Requirement	Maintenance Interval	Corrective Action
Pumps	1. Absence of leaks 2. Ability to draw manufacturer required vacuum and flow	Every 500 hours of operation or 6 months, whichever is less	1. Visual inspection 2. Clean 3. Replace worn parts 4. Leak check
Flow Measuring Device	1. Free mechanical movement 2. Absence of malfunction	Every 500 hours of operation or 6 months, whichever is less After each test, if used in H_2S sampling or other corrosive atmospheres	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero, span gas	As required by the manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling Systems	Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling Lines	Sample degradation less than 2%	After each test or test series	Blow filtered air through line until dry

Appendix B.2

ARB Certification

State of California
AIR RESOURCES BOARD

Executive Order G-94-028

Approval to Carnot
To Conduct Testing as an Independent Contractor

WHEREAS, the Air Resources Board (ARB), pursuant to Section 41512 of the California Health and Safety Code, has established the procedures contained in Section 91200-91220, Title 17, California Code of Regulations, to allow the use of independent testers for compliance tests required by the ARB; and

WHEREAS, pursuant to Sections 91200-91220, Title 17, California Code of Regulations, the Executive Officer has determined that Carnot meets the requirements of the ARB for conducting ARB Test Methods 1, 2, 3, 4, 5, 6, 8, 10, and 100 (NOx, O2) when the following conditions are met:

1. Carnot conducts ARB Test Method 100 for O2 using a Teledyne 326 analyzer with either a A5 or a B1 sensor, or a paramagnetic analyzer.

NOW, THEREFORE, BE IT ORDERED that Carnot is granted an approval, from the date of execution of this order, until June 30, 1995 to conduct the tests listed above, subject to compliance with Section 91200-91220, Title 17, California Code of Regulations.

BE IT FURTHER ORDERED that during the approved period the Executive Officer or his or her authorized representative may field audit one or more tests conducted pursuant to this order for each type of testing listed above.

Executed this 29TH day of JUNE 1994, at Sacramento, California.

James J. Morgester, Chief
Compliance Division

STATE OF CALIFORNIA
AIR RESOURCES BOARD
2020 L STREET
P O. BOX 2815
SACRAMENTO, CA 95812

PETE WILSON, Governor

July 8, 1994

Mr. Michael L. Schmitt
Carnot
15991 Red Hill Avenue, Suite 110
Tustin, California 92680

Dear Mr. Schmitt:

Testing Approval

We are pleased to inform you that we have renewed your approval to conduct the types of testing listed in the enclosed Executive Order. This approval is valid until June 30, 1995 during which time a field audit of your company's testing ability may be conducted. We have also enclosed a certificate of approval.

Should you have any questions or need further assistance, please contact Ms. Kathryn Gugeler at (916) 327-1521 or Mr. David Tribble at (916) 323-2217. All correspondence should be addressed to me at the post office box above.

Sincerely,

James J. Morgester, Chief
Compliance Division

Enclosures

cc: Mr. Ed Jeung
Department of Health Services
Air and Industrial Hygiene Laboratory
2151 Berkeley Way
Berkeley, California 94704

State of California

Air Resources Board

Approved Independent Contractor

Carnot

This is to certify that the company listed above has been approved by the Air Resources Board to conduct compliance testing pursuant to Section 91207, Title 17, California Code of Regulations, until June 30, 1995, for those test methods listed below:

ARB Source Test Methods:
1, 2, 3, 4, 5, 6, 8, 10, 100(NOx, O2)

James J. Morgester, Chief
Compliance Division

Laura McKinney, Manager
Certification and Investigation Section

Appendix B.3

Calibration Data

CARNOT
SPAN GAS RECORD

CLIENT/LOCATION: UCOS - Colmac DATE: 6/27/96

BY: CS

GAS	SPAN CYLINDER		AUX. SPAN CYLINDER	
	CYLINDER NO.	CONCENTRATION	CYLINDER NO.	CONCENTRATION
ZERO		99.999 %		
NOx	AAL3583	88.54	AAL1240 J	47.51
O_2	ALM045927	8.937	ALM05739	12.15
CO				
CO_2	ALM 045927	22.43	ALM05739	15.16
SO_2				

CARNOT
INSTRUMENT LINEARITY

	ANALYZER				
	O_2	CO_2	CO	NOx	SO_2
ANALYZER RANGE	0-25	—	—	0-100	—
SET TO HIGH STD (80-90% OF RANGE)	20.9	—	—	88.5	—
ACTUAL VALUE OF LOW STD	12.15	—	—	47.51	—
AS-FOUND LOW STD (50-60% OF RANGE)	12.33	—	—	48.9	—
DIFFERENCE IN % OF FULL SCALE	0.5	—	—	+1.3	—

% ERROR CALCULATION:

$$\frac{\text{(AS FOUND - ACTUAL VALUE OF SPAN)}}{\text{RANGE}} \times 100$$

ALLOWABLE DEVIATION IS 2% OF FULL SCALE (2 SQUARES ON STRIP CHART).

PMF-009

CARNOT

CARNOT
SPAN GAS RECORD

CLIENT/LOCATION: UCOS Colmac DATE: 6-28-94

BY: D. U.

GAS	SPAN CYLINDER		AUX. SPAN CYLINDER	
	CYLINDER NO.	CONCENTRATION	CYLINDER NO.	CONCENTRATION
ZERO				
NOx	AAL3583	88.54	AAL12400	47.51
O_2	ALM-045927	8.937	ALM-739	12.45
CO				
CO_2				
SO_2				

CARNOT
INSTRUMENT LINEARITY

	ANALYZER				
	O_2	CO_2	CO	NOx	SO_2
ANALYZER RANGE	0-25			0-100	
SET TO HIGH STD (80-90% OF RANGE)	20.74			88.5	
ACTUAL VALUE OF LOW STD	12.45			47.51	
AS-FOUND LOW STD (50-60% OF RANGE)	12.55			47.00	
DIFFERENCE IN % OF FULL SCALE	.5%			.5%	

% ERROR CALCULATION:

$$\frac{(\text{AS FOUND} - \text{ACTUAL VALUE OF SPAN})}{\text{RANGE}} \times 100$$

ALLOWABLE DEVIATION IS 2% OF FULL SCALE (2 SQUARES ON STRIP CHART).

PMP-009

CARNOT

CARNOT
CEM PERFORMANCE DATA

CLIENT/LOCATION: UCOS-Colma DATE: 6/28/94

BY: SS

SYSTEM CONFIGURATION F600

ANALYZERS IN SERVICE

ANALYZERS:	O_2	CO_2	CO	NOx
MODEL:	Teledyne	PIR 2000	48	10S
SERIAL NO.:				

PROBE	Main	Aux
LENGTH:	6'	4'
LINER MATERIAL:	SS	SS
HEATED PROBE (Y/N):	no	no
HEATED LINE (Y/N):	Yes	Yes

SAMPLE LINE		
LENGTH:	50'	50'
LINER MATERIAL:	teflon	teflon
SYSTEM BIAS LINE:	teflon	teflon

ON-STACK CONDITIONER:	
IN SERVICE (Y/N):	Yes
KNOCK-OUT CONDITION (CHECK FLOW):	✓
COOLANT:	ICE

SAMPLE CONDITIONER:	
CONDENSER-VACUUM SIDE (CHECK FLOW):	✓
CONDENSER-PRESSURE SIDE (CHECK FLOW):	✓
CONDENSER TEMPERATURE:	40
FILTER CONDITION (COND. OR DATE LAST CHANGED):	5D 4/94

SYSTEM LEAK CHECK	Main	Aux
PRE-TEST (cfh):	0.0	0.0
POST-TEST (cfh):		

LEAK RATE (%) = $\frac{\text{POST-TEST (cfh)}}{\text{SYSTEM FLOW RATE (cfm) x 60}}$ x 100 = _____ %

NOx CONVERSION EFFICIENCY

HIGH CAL NOx	
HIGH CAL NO (AS FOUND)	1
LOW CAL NOx	
LOW CAL NO (AS FOUND)	1

OPERATING CONDITIONS

SAMPLE PRESSURE:	SYSTEM RESPONSE TIME CHECK
SAMPLE VACUUM:	UPSCALE: _____ sec.
NOx VACUUM:	DOWNSCALE: _____ sec.

PMF-011

CARNOT

Scott Specialty Gases, Inc.

2600 CAJON BOULEVARD, SAN BERNARDINO, CA 92411 (909) 887-2571 FAX: (909) 887-0549

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
CARNOT
RICK MADRIGAL
15991 RED HILL AVE
TUSTIN, CA 92680

Assay Laboratory
Scott Specialty Gases
2600 Cajon Boulevard
San Bernardino, CA 92411

Purchase Order 1818
Project # 30380.003

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards, Procedure G1, September 1993.

Cylinder Number ALM045739 Certification Date 03-15-94 Exp. Date 03-15-97
Cylinder Pressure+ 2000 PSIG

ANALYZED CYLINDER

Components	Certified Concentration	Analytical Uncertainty*
(CARBON DIOXIDE)	15.16 %	± 1 % NIST Traceable
(OXYGEN)	12.45 %	
(Nitrogen)	Balance Gas	

+Do not use when cylinder pressure is below 150 psig.
*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type/Sample No.	Expiration Date	Cylinder Number	Concentration
GMIS	06-94	A018082	18.97 % CO2 IN N2
GMIS	06-94	A6513	12.45 % O2 IN N2

INSTRUMENTATION

Instrument/Model/Serial #	Last Date Calibrated	Analytical Principle
CO2:Horiba / OPE-135C / 56553902	02-22-94	NDIR
O2:Horiba / OPE-335 / 850557042	02-25-94	Magnetopneumatic

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Carbon Dioxide

First Triad Analysis

Date: 03-15-94	Response Units: mv	
Z1= 0.00	R1= 97.0	T1= 85.9
R2= 97.0	Z2= 0.00	T2= 85.8
Z3= 0.00	T3= 85.8	R3= 97.0
Avg. Conc. of Cust Cyl.		15.16 %

Second Triad Analysis

Date:	Response Units: mv	
Z1=	R1=	T1=
R2=	Z2=	T2=
Z3=	T3=	R3=
Avg. Conc. of Cust Cyl.		

Calibration Curve

Concentration= Ax^3+Bx^2+Cx+D
A =0.000007988
B =0.0002062
C =0.1000
D =-0.0001333

Oxygen

First Triad Analysis

Date: 03-15-94	Response Units: mv	
Z1= 0.00	R1= 94.1	T1= 49.8
R2= 94.1	Z2= 0.00	T2= 49.8
Z3= 0.00	T3= 49.8	R3= 94.1
Avg. Conc. of Cust Cyl.		12.45 %

Second Triad Analysis

Date:	Response Units: mv	
Z1=	R1=	T1=
R2=	Z2=	T2=
Z3=	T3=	R3=
Avg. Conc. of Cust Cyl.		

Calibration Curve

Concentration= $Ax+B$
A =0.2500
B =-0.004586

Date:	Response Units: mv	
Z1=	R1=	T1=
R2=	Z2=	T2=
Z3=	T3=	R3=
Avg. Conc. of Cust Cyl.		

Date:	Response Units: mv	
Z1=	R1=	T1=
R2=	Z2=	T2=
Z3=	T3=	R3=
Avg. Conc. of Cust Cyl.		

Concentration=

Special Notes:

ANALYST

Scott Specialty Gases, Inc.

2600 CAJON BOULEVARD, SAN BERNARDINO, CA 92411 (909) 887-2571 FAX (909) 887-0549

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
CARNOT
RICK MADRIGAL
15991 RED HILL AVE
SUITE 110
TUSTIN, CA 92680

Assay Laboratory
Scott Specialty Gases
2600 Cajon Boulevard
San Bernardino, CA 92411

Purchase Order 1914
Project # 30667 009

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay and Certification of Gaseous Calibration Standards, Procedure G1, September 1993.

Cylinder Number ALM045927
Cylinder Pressure+ 1900 PSIG
Certification Date 03-30-94
Exp. Date 03-30-97

ANALYZED CYLINDER

Components	Certified Concentration	Analytical Uncertainty*
(CARBON DIOXIDE)	22.43 %	± 1 % NIST Traceable
(OXYGEN)	8.937 %	
(Nitrogen)	Balance Gas	

+Do not use when cylinder pressure is below 150 psig.
*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type/Sample No.	Expiration Date	Cylinder Number	Concentration
CRM1675	06-94	ALM001136	14.08 % CO2/N2
GMIS	06-94	AJ0868	9.520 % O2/N2

INSTRUMENTATION

Instrument/Model/Serial #	Last Date Calibrated	Analytical Principle
CO2:PIR2000-ACUBLEND	03-24-94	NDIR
O2:Horiba / OPE-335 / 850557042	03-30-94	Magnetopneumatic

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

Carbon Dioxide

First Triad Analysis

Date: 03-30-94 Response Units: mv

Z1=	0.00	R1=	72.9	T1=	92.2
R2=	72.9	Z1=	0.00	T2=	92.2
Z3=	0.00	T3=	92.2	R3=	72.9

Avg. Conc. of Cust Cyl. 22.43 %

Second Triad Analysis

Date: Response Units: mv

Z1=		R1=		T3=	
R2=		Z2=		T2=	
Z3=		T3=		R3=	

Avg. Conc. of Cust Cyl.

Calibration Curve

Concentration= $Ax^4+Bx^3+Cx^2+Dx+E$

A =0.000000192
B =-0.00001975
C =0.001882
D =0.08535
E =0.002942

Oxygen

First Triad Analysis

Date: 03-30-94 Response Units: mv

Z1=	0.00	R1=	95.3	T1=	89.4
R2=	95.3	Z2=	0.00	T2=	89.4
Z3=	0.00	T3=	89.3	R3=	95.3

Avg. Conc. of Cust Cyl. 8.930 %

Second Triad Analysis

Date: Response Units: mv

Z1=		R1=		T1=	
R2=		Z2=		T2=	
Z3=		T3=		R3=	

Avg. Conc. of Cust Cyl.

Calibration Curve

Concentration= Ax + B

A =0.09999
B =0.0004275

Date: Response Units: mv

Z1=		R1=		T1=	
R2=		Z2=		T2=	
Z3=		T3=		R3=	

Date: Response Units: mv

Z1=		R1=		T1=	
R2=		Z2=		T2=	
Z3=		T3=		R3=	

Concentration=

Analyst:

CARNOT
3-DIMENSIONAL VELOCITY PROBE CALIBRATION
PITCH ANGLE vs. F1
PROBE ID: B-2455



Pitch Angle = 63.09X + 23.69X^2 - 24.505X^3 - 33.312X^4 + 7.5203X^5 + 11.669X^6

Performed By: MM/RM
Date: 6/13/94

CARNOT
3-DIMENSIONAL VELOCITY PROBE CALIBRATION
F2 vs. PITCH ANGLE
PROBE ID: B-2455



$F2 = 0.997 - 0.0007X + 3E\text{-}5X^2 + 8E\text{-}7X^3 + 1E\text{-}8X^4 - 3E\text{-}10X^5 + 3E\text{-}12X^6$

Performed By: MM/RM
Date: 5/18/94

APPENDIX C
DATA SHEETS

Appendix C.1

Sample Locations

CARNOT

SAMPLING POINT LOCATION DATA - EPA METHOD 1

PLANT: Vcet - Olmec DATA BY: EF

DATE: 6/27/96

TEST LOCATION: Unit 2 duct



Diagram of Sampling Location

UPSTREAM DIST./DIA.: 17/

DOWNSTREAM DIST./DIA.: 3/

COUPLING LENGTH: 8"

NO. OF SAMPLING PTS.: 42

STACK DIMENSION: 47" x 119"

STACK AREA, FT²: 38.8

SAMPLE POINT	% OF DIAMETER	IN. FROM NEAR WALL	IN. FROM NOZZLE*
1		3.4	11.42
2		10.3	18.3
3		17.14	25.14
4		24.	32
5		30.86	38.86
6		37.7	45.71
7		44.5	52.57

*INCHES FROM WALL PLUS COUPLING LENGTH

PMF-002

Appendix C.2

CEM Data

CARNOT
CONTINUOUS EMISSIONS MEASUREMENTS

CLIENT: UCOS - Colmac
DATE: 6/28/98 - EP
OPERATOR:
TEST LOCATION: Unit 1 outlet
TEST NUMBERS: 1-1 Stack

AMBIENT TEMP., DB/WB: ~115
BAROMETRIC PRESSURE: 29.80
DUCT STATIC PRESSURE: -0.7
FUEL: Bo Mud

TEST NO.	SAMPLE TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO ___% ___ DRY		
			O_2 Ref	O_2	CO	NOx	NO	NO_2	SO_2	CO	NOx	SO_2
		Zero / Span	.3/122	1/124								
1-1	~~1215~~ / 1221	A5	6.9	6.9								
	1221 / 1224	A4	7.2	7.1								
	1224 / 1227	A3	6.7	6.7								
	1227 / 1230	A2	7.0	7.2								
	1230 / 1233	A1	7.1	8.0								
	1236 / 1239	B5	6.5	6.5								
	1239 / 1242	B4	6.7	6.7								
	1242 / 1245	B3	6.9	6.6								
	1245 / 1248	B2	6.3	6.2								
	1248 / 1251	B1	6.5	6.5								

COMMENTS:

CARNOT
CONTINUOUS EMISSIONS MEASUREMENTS

CLIENT: UCS - Column
DATE: 6/28/94
OPERATOR: EP
TEST LOCATION: Unit 1
TEST NUMBERS: 1-1 Start

AMBIENT TEMP., DB/WB:
BAROMETRIC PRESSURE:
DUCT STATIC PRESSURE:
FUEL: Bio Mass

TEST NO.	SAMPLE TIME	SAMPLE POINT/ CONDITION	Ref — DRY, UNCORRECTED							CORRECTED TO ___% ___, DRY		
			O_2	$\%O_2$	CO	NOx	NO	NO_2	SO_2	CO	NOx	SO_2
	1254/1257	C5	6.6	6.5								
	1257/1300	C4	6.3	6.2								
	1300/1303	C3	6.4	6.4								
	1305/1306	C2	6.9	6.8								
	1306/1309	C1	6.7	6.7								
	1312/1315	D5	6.7	6.6								
	1315/1318	D4	6.9	6.8								
	1318/1321	D3	6.7	6.7								
	1321/1324	D2	6.6	6.6								
	1324/1327	D1	6.7	6.7								

COMMENTS:

PMF-013

CARNOT

(5)

CARNOT
CONTINUOUS EMISSIONS MEASUREMENTS

CLIENT: UCS - Colmac

DATE: 6/28/94

OPERATOR: SG

TEST LOCATION: Unit 2 Outlet

TEST NUMBERS: 1-1 Straw

AMBIENT TEMP., DB/WB:

BAROMETRIC PRESSURE:

DUCT STATIC PRESSURE:

FUEL:

TEST NO.	SAMPLE TIME	SAMPLE POINT/ CONDITION	Reb DRY, UNCORRECTED							CORRECTED TO ___% ___, DRY		
			O_2	O_2	CO	NOx	NO	NO_2	SO_2	CO	NOx	SO_2
1-1	1330 / 1333	E-5	7.0	6.9								
	1339 / 1336	E-4	6.6	6.6								
	1336 / 1339	E-3	6.6	6.6								
	1339 / 1342	E-2	6.9	6.8								
	1342 / 1345	E-1	6.7	6.6								
	1348 / 1351	F-5	6.5	6.5								
	1351 / 1354	F-4	6.2	6.2								
	1354 / 1357	F-3	6.8	6.8								
	1357 / 1400	F-2	6.8	6.8								
	1400 / 1403	F-1	6.8	6.8								
	1420 / 1409	A-1	6.5	6.5								
	SYS	ZERO / SPAN	.3 / 12.1	.1 / 13.1								

COMMENTS:

PMF-013

CARNOT

CARNOT
CONTINUOUS EMISSIONS MEASUREMENTS

CLIENT: UCOS- Gilroy

DATE: 6/28/94

OPERATOR: EF

TEST LOCATION: 2-2-CEM

TEST NUMBERS:

AMBIENT TEMP., DB/WB:

BAROMETRIC PRESSURE:

DUCT STATIC PRESSURE:

FUEL:

TEST NO.	SAMPLE TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO ___% ___, DRY		
			O_2 REF	O_2	CO	NOx	NO	NO_2	SO_2	CO	NOx	SO_2
	SYS	ZERO SPAN	.3/12.2	.1/12.4								
	933/936	F5	7.0	7.0								
	936/939	F4	6.4	6.5								
	939/942	F3	7.3	7.4								
	942/945	F2	7.0	7.0								
	945/948	F1	6.7	6.7								
	951/954	E5	6.5	6.5								
	954/957	E-4	6.7	6.8								
	957/1000	E-3	7.1	7.1								
	1003/1006	E-2	6.9	7.0								
	1006/1009	E-1	6.7	6.8								

COMMENTS:

PMF-013

CARNOT

CARNOT
CONTINUOUS EMISSIONS MEASUREMENTS

CLIENT: UCOS - Colmac

DATE: 6/28/94

OPERATOR: EC

TEST LOCATION:

TEST NUMBERS:

AMBIENT TEMP., DB/WB:

BAROMETRIC PRESSURE:

DUCT STATIC PRESSURE:

FUEL:

TEST NO.	SAMPLE TIME	SAMPLE POINT/ CONDITION	Ref DRY, UNCORRECTED							CORRECTED TO ___% ___, DRY		
			O_2	O_2	CO	NOx	NO	NO_2	SO_2	CO	NOx	SO_2
2-2	1009/1012	D-5	6.9	7.0								
	1103/1105	D-4	6.3	6.4								
	1015/1018	D-3	7.2	7.2								
	1018/1021	D-2	7.7	7.7								
	1021/1024	D-1	7.0	7.0								
	1033/1036	C-5	6.5	6.4								
	1036/1039	C-4	6.6	6.6								
	1039/1042	C-3	6.5	6.6								
	1042/1045	C-2	6.4	6.4								
	1045/1048	C-1	7.4	7.5								

COMMENTS:

PMF-013

CARNOT

CARNOT
CONTINUOUS EMISSIONS MEASUREMENTS

CLIENT: VCOS - Columbus
DATE: 6/28/96
OPERATOR: GG
TEST LOCATION: Outlet #2
TEST NUMBERS: 2-2-ST

AMBIENT TEMP., DB/WB: 105
BAROMETRIC PRESSURE: 29.92
DUCT STATIC PRESSURE:
FUEL: No Mass

TEST NO.	SAMPLE TIME	SAMPLE POINT/ CONDITION	DRY, UNCORRECTED							CORRECTED TO ___% ___ DRY		
			O_2 Ref	O_2	CO	NOx	NO	NO_2	SO_2	CO	NOx	SO_2
	1051/1054	B-5	6.0	6.1								
	1054/1057	B-4	6.2	6.3								
	1057/1100	B-3	6.5	6.6								
	1100/1103	B-2	6.7	6.8								
	1103/1106	B-1	6.6	6.7								
	1109/1112	A-5	7.1	7.3								
	1112/1115	A-4	6.7	6.9								
	1115/1118	A-3	7.4	7.5								
	1118/1121	A-2	6.7	6.8								
	1121/1124	A-1	6.4	6.6								
	GAS	Zero/Span	.3/12.2	.1/12.4								

COMMENTS:

PMF-013

CARNOT

Appendix C.3

3D Flow Data

CARNOT

3-DIMENSIONAL VELOCITY DATA

Client/Location: UCOS Colmac — Date: 6-28-94

Sample Location: Unit 1 outlet — Data Taken By: Dave Wonderly

Unit No: 1 — Test Description: 3-D traverse

Test No: 1-3-BD-traverse — Pilot I.D. No.:

Barometric Pressure (in Hg): — Pre-Test Leak Check: 0.4

Static Pressure in Stack (inwg): — Post-Test Leak Check: 0.4

Time	Port	Point	Yaw Angle (Degrees)	Velocity (P1-P2)	Pitch (P4-P5)	Temperature (F)
	D	7	-10	.45	0	413
		6	-6	.47	0	413
		5	-5	.47	+.01	414
1215		4	0	.40	+.01	414
		3	-1	.39	+.01	416
		2	0	.34	+0	416
		1	0	.31	+.01	415
	~~B~~ C	7	-10	.4	-.04	415
	~~B~~ C	6	-10	.35	-.02	416
		5	-5	.37	-.00	416
		4	0	.35	0	417
		3	+5	.41	+.01	417
		2	+8	.4	+.02	417
		1	+10	.33	+.03	417
	B	7	-5	.56	0	416
		6	-10	.57	0	417
		5	-6	.48	0	417
		4	-8	.34	-.02	417
		3	0	.26	+.03	417
		2	+7	.26	+.03	417
		1	+8	.28	+.01	417

Note: Clockwise rotation of the probe corresponds to a positive yaw angle: > 0 or > 90 degrees.

3D_DATA.XLS
2/14/94
8:03 PM

CARNOT

3-DIMENSIONAL VELOCITY DATA

Client/Location: UCOS Colmac Date: 6-28

Sample Location: Unit / outlet Data Taken By: Dave W.

Unit No: 1 Test Description: 3-D traverse

Test No: 1-7-3D-traverse Pitot I.D. No.:

Barometric Pressure (in Hg) 29.80 Pre-Test Leak Check:

Static Pressure in Stack (inwg): Post-Test Leak Check:

Time	Port	Point	Yaw Angle (Degrees)	Velocity (P1-P2)	Pitch (P4-P5)	Temperature (F)
	A	7	-10	.59	-.07	415
		6	-8	.48	-.07	416
		5	-6	.48	-.07	418
		4	0	.5	-.05	418
		3	-8	.57	-.04	419
		2	0	.6	-.05	419
		1	0	.6	-.07	419
	E	7	+5	.57	.0	419
		6	-8	.55	0	420
		5	0	.56	0	420
		4	0	.6	0	420
		3	-3	.58	0	420
		2	-2	.6	-.03	420
		1	-2	.58	-.02	420
	C	7	-4	.5	-.01	418
		6	0	.6	-.03	418
		5	+2	.55	-.04	419
		4	00	.52	-.04	419
		3	0	.62	-.04	419
		2	0	.62	-.04	419
		1	0	.60	-.03	419

Note: Clockwise rotation of the probe corresponds to a positive yaw angle: > 0 or > 90 degrees.

3D_DATA.XLS
2/14/94
8:03 PM

CARNOT

3-DIMENSIONAL VELOCITY DATA

Client/Location: UCCE

Sample Location: Unit 2 outlet

Unit No: 2

Test No: 2-2-3D

Barometric Pressure (in Hg):

Static Pressure in Stack (inwg): -0.75

Date: 8-28-95

Data Taken By: D. C

Test Description: 3-D

Pitot I.D. No.:

Pre-Test Leak Check:

Post-Test Leak Check:

Time	Port	Point	Yaw Angle (Degrees)	Velocity (P1-P2)	Pitch (P4-P5)	Temperature (F)
1035	A	7	-6	.55	-.05	439
		6	-9	.45	-.05	439
		5	-12	.45	-.05	439
		4	-3	.5	-.05	439
		3	-9	.6	-.04	439
		2	-8	.6	-.05	439
		1	-8	.55	-.06	440
	B	7	+5	.7	-.00	439
		6	-7	.65	0	439
		5	0	.57	0	439
		4	-1	.48	0	439
		3	-2	.72	0	439
		2	-3	.25	0	438
		1	-15	.27	-.02	438
	C	7	0	.41	-.01	437
		6	0	.42	-.02	436
		5	0	.37	-.01	437
		4	-2	.37	+.01	437
		3	-6	.36	+.02	437
		2	-7	.4	+.02	437
		1	-9	.36	+.02	437

Note: Clockwise rotation of the probe corresponds to a positive yaw angle: > 0 or > 90 degrees

3D_DATA.XLS
2/14/94
8:03 PM

CARNOT

3-DIMENSIONAL VELOCITY DATA

Client/Location: VCOS Colmac

Sample Location: Outlet

Unit No: 2

Test No: 2-2-3D-Vel

Barometric Pressure (in Hg): 29.82

Static Pressure in Stack (in.g):

Date: 6-27-94

Data Taken By: Dave Wonderly

Test Description: 3-D

Pitot I.D. No.:

Pre-Test Leak Check: O.K

Post-Test Leak Check: O.K

Time	Port	Point	Yaw Angle (Degrees)	Velocity (P1-P2)	Pitch (P4-P5)	Temperature (F)
	F	7	-7°	.55	-.05	
		6	-7°	.57	-.04	446
		5	-7°	.50	-.06	441
		4	-6°	.59	-.03	443
		3	-1	.66	-.03	441
		2	-8°	.60	0	442
		1	-10	.52	+.07	445
	E	7	-9°	.52	0	441
		6	-10°	.52	+.01	442
		5	-5°	.54	+.02	442
		4	-7°	.55	0	442
		3	-3°	.53	0	441
		2	-9°	.53	0	441
		1	-10°	.55	+.02	440
	D	7	0	.49	0	440
		6	+1	.45	+.02	438
		5	-2	.42	+.02	437
		4	0	.39	+.01	437
		3	0	.36	0	437
		2	-3°	.30	-.01	437
		1	+2	.25	0	437

Note: Clockwise rotation of the probe corresponds to a positive yaw angle: > 0 or > 90 degrees.

3D_DATA.XLS
2/14/94
8:03 PM

APPENDIX D
CALCULATIONS

3D VELOCITY - DATA AND WORKSHEET

Client:	UCOS COLMAC	Date:	
Unit:	# 1	Data By:	EF
Sample Location:	Outlet duct	Baro. Pressure, in Hg.:	29.90
Test No.:	1-1-3d	Static Pressure, in WG:	-0.78
Probe ID No.:	B-2131	Abs. Pressure, in Hg.:	29.84
Unit Load:		Average O2, % dry:	6.70
Test Date:	6/28/94	Average CO2, % dry:	12.00
Time (Start/Stop):	0950/1145	Moisture Content, %:	15.00
		Molecular Weight, wet:	28.36

Sample Point		Yaw Angle deg.	Pitch P4-P5 in WG	Total P1-P2 in WG	Stack Temp. F	P4-P5/ P1-P2 in WG	Pitch Angle deg.	Pt-Ps/ P1-P2 in WG	Pt-Ps in WG	Result Angle deg.	Velocity uncorr.* fps	Velocity Axial fps
A	7	-10	-0.03	0.58	415	-0.05	-3.2	1.00	0.58	10.5	66.1	65.0
A	6	-8	-0.03	0.48	416	-0.06	-3.8	1.00	0.48	8.9	60.2	59.4
A	5	-6	-0.03	0.48	418	-0.06	-3.8	1.00	0.48	7.1	60.2	59.8
A	4	0	-0.05	0.50	418	-0.10	-6.1	1.00	0.50	6.1	61.5	61.2
A	3	0	-0.04	0.57	419	-0.07	-4.3	1.00	0.57	4.3	65.7	65.5
A	2	0	-0.05	0.60	419	-0.08	-5.1	1.00	0.60	5.1	67.4	67.2
A	1	0	-0.03	0.60	419	-0.05	-3.1	1.00	0.60	3.1	67.4	67.3
E	7	-5	0.00	0.53	419	0.00	0.0	1.00	0.53	5.0	63.2	63.0
E	6	-8	0.00	0.55	420	0.00	0.0	1.00	0.55	8.0	64.4	63.8
E	5	0	0.00	0.56	420	0.00	0.0	1.00	0.56	0.0	65.0	65.0
E	4	0	0.00	0.60	420	0.00	0.0	1.00	0.60	0.0	67.3	67.3
E	3	-3	0.00	0.58	420	0.00	0.0	1.00	0.58	3.0	66.2	66.1
E	2	-2	0.03	0.60	420	0.05	3.2	1.00	0.60	3.8	67.2	67.1
E	1	-2	0.02	0.58	420	0.03	2.2	1.00	0.58	3.0	66.1	66.0
F	7	-4	-0.01	0.50	418	-0.02	-1.3	1.00	0.50	4.2	61.4	61.2
F	6	0	-0.03	0.60	418	-0.05	-3.1	1.00	0.60	3.1	67.3	67.2
F	5	2	-0.04	0.55	419	-0.07	-4.5	1.00	0.55	4.9	64.5	64.3
F	4	0	-0.04	0.52	419	-0.08	-4.7	1.00	0.52	4.7	62.8	62.5
F	3	0	-0.04	0.62	419	-0.06	-4.0	1.00	0.62	4.0	68.5	68.3
F	2	0	-0.04	0.62	419	-0.06	-4.0	1.00	0.62	4.0	68.5	68.3
F	1	0	-0.03	0.60	419	-0.05	-3.1	1.00	0.60	3.1	67.4	67.3
D	7	-10	0.00	0.45	413	0.00	0.0	1.00	0.45	10.0	58.1	57.2
D	6	-6	0.01	0.47	413	0.02	1.4	1.00	0.47	6.2	59.3	59.0
D	5	-5	0.01	0.43	414	0.02	1.5	1.00	0.43	5.2	56.8	56.5
D	4	0	0.01	0.40	414	0.03	1.6	1.00	0.40	1.6	54.7	54.7
D	3	1	0.01	0.39	416	0.03	1.6	1.00	0.39	1.9	54.1	54.1
D	2	0	0.00	0.34	416	0.00	0.0	1.00	0.34	0.0	50.6	50.6
D	1	0	0.01	0.31	415	0.03	2.1	1.00	0.31	2.1	48.2	48.2
C	7	-10	-0.04	0.40	415	-0.10	-6.1	1.00	0.40	11.7	54.9	53.8
C	6	-10	-0.02	0.35	416	-0.06	-3.5	1.00	0.35	10.6	51.4	50.5
C	5	-5	0.00	0.37	416	0.00	0.0	1.00	0.37	5.0	52.7	52.5
C	4	0	0.00	0.35	417	0.00	0.0	1.00	0.35	0.0	51.3	51.3
C	3	5	0.01	0.41	417	0.02	1.6	1.00	0.41	5.2	55.5	55.3
C	2	8	0.02	0.40	417	0.05	3.2	1.00	0.40	8.6	54.8	54.2
C	1	10	0.03	0.33	417	0.09	5.9	0.99	0.33	11.6	49.8	48.7
B	7	-9	0.00	0.58	416	0.00	0.0	1.00	0.58	9.0	66.0	65.2
B	6	-10	0.00	0.57	417	0.00	0.0	1.00	0.57	10.0	65.5	64.5
B	5	-6	0.00	0.48	417	0.00	0.0	1.00	0.48	6.0	60.1	59.8
B	4	-8	0.02	0.34	417	0.06	3.8	0.99	0.34	8.8	50.5	49.9
B	3	0	0.03	0.26	417	0.12	7.6	0.99	0.26	7.6	44.2	43.8
B	2	7	0.03	0.26	417	0.12	7.6	0.99	0.26	10.3	44.2	43.5
B	1	8	0.01	0.28	417	0.04	2.3	1.00	0.28	8.3	45.9	45.4

RESULTS

0.48

Yaw Angle:	2.0 degrees	Stack Temperature:	417 F
Pitch Angle:	-0.4 degrees	Velocity*:	59.45 fps (feet per sec.)
Resultant Angle:	5.6 degrees	Axial Velocity:	59.08 fps
Standard Deviation:	3.3 degrees		

*velocity in the direction of flow

CARNOT
15991 Red Hill Ave., Suite 110
714-259-9520
FAX 714-259-0372

40985.XLS/1-1 3d

STRATIFICATION CHECK

Client: UCOS COLMAC
Project #: 1409-40950
Unit No: 1.0
Date: 6/28/94

Point	O_2 pt	Ref O_2	% Diff	Point	O_2 pt	Ref O_2	% Diff
A5	6.9	6.9	0.0%	D5	6.5	6.4	-1.6%
A4	7.2	7.1	-1.4%	D4	6.6	6.6	0.0%
A3	6.7	6.7	0.0%	D3	6.7	6.7	0.0%
A2	7.0	7.2	2.8%	D2	6.6	6.6	0.0%
A1	6.5	6.5	0.0%	D1	6.7	6.7	0.0%
B5	6.5	6.5	0.0%	E5	7.0	6.9	-1.4%
B4	6.7	6.7	0.0%	E4	6.6	6.6	0.0%
B3	6.7	6.6	-1.5%	E3	6.6	6.6	0.0%
B2	6.3	6.2	-1.6%	E2	6.9	6.8	-1.5%
B1	6.5	6.5	0.0%	E1	6.7	6.6	-1.5%
C5	6.6	6.5	-1.5%	F5	6.5	6.5	0.0%
C4	6.3	6.2	-1.6%	F4	6.2	6.2	0.0%
C3	6.4	6.4	0.0%	F3	6.8	6.8	0.0%
C2	6.9	6.8	-1.5%	F2	6.8	6.8	0.0%
C1	6.7	6.7	0.0%	F1	6.8	6.8	0.0%

O2 Stratification= -0.4%

CARNOT
15991 Red Hill Ave. Suite 110
Tustin, California 92680
714-259-9520
FAX 714-259-0372

3D VELOCITY - DATA AND WORKSHEET

Client:	UCD5 COLMAC
Unit:	# 2
Sample Location:	Outlet duct
Test No.:	2-2-3d
Probe ID No.:	B-2131
Unit Load:	
Test Date:	6/28/94
Time (Start/Stop):	0950/1145

Date:	
Data By:	EF
Baro. Pressure, in Hg.:	29.90
Static Pressure, in WC:	-0.78
Abs. Pressure, in Hg:	29.84
Average O2, % dry:	6.70
Average CO2, % dry:	12.00
Moisture Content, %:	15.00
Molecular Weight, wet:	28.36

Sample Point		Yaw Angle deg.	Pitch P4-P5 in WG	Total P1 P2 in WG	Stack Temp. F	P4-P5/ P1-P2 in WG	Pitch Angle deg.	Pt-Ps/ P1-P2 in WG	Pt-Ps in WG	Result Angle deg.	Velocity uncorr.* fps	Axial fps
A	7	-6	-0.05	0.55	439	-0.09	-5.5	1.00	0.55	8.1	65.3	64.6
A	6	-9	-0.05	0.45	439	-0.11	-6.7	1.00	0.45	11.2	59.1	58.0
A	5	-12	-0.05	0.45	439	-0.11	-6.7	1.00	0.45	13.7	59.1	57.4
A	4	-3	-0.05	0.50	439	-0.10	-6.1	1.00	0.50	6.8	62.3	61.8
A	3	-9	-0.04	0.60	439	-0.07	-4.1	1.00	0.60	9.9	68.1	67.1
A	2	-8	-0.05	0.60	439	-0.08	-5.1	1.00	0.60	9.5	68.2	67.3
A	1	-8	0.00	0.55	440	0.00	0.0	1.00	0.55	8.0	65.2	64.5
B	7	5	0.00	0.70	439	0.00	0.0	1.00	0.70	5.0	73.5	73.2
B	6	-3	0.00	0.65	439	0.00	0.0	1.00	0.65	3.0	70.8	70.7
B	5	0	0.00	0.57	439	0.00	0.0	1.00	0.57	0.0	66.3	66.3
B	4	-1	0.00	0.48	439	0.00	0.0	1.00	0.48	1.0	60.9	60.8
B	3	-2	0.00	0.32	439	0.00	0.0	1.00	0.32	2.0	49.7	49.7
B	2	-3	0.00	0.25	438	0.00	0.0	1.00	0.25	3.0	43.9	43.8
B	1	-15	-0.02	0.27	438	-0.07	-4.5	1.00	0.27	15.7	45.7	44.0
C	7	0	-0.01	0.41	437	-0.02	-1.5	1.00	0.41	1.5	56.2	56.2
C	6	0	-0.02	0.42	436	-0.05	-2.9	1.00	0.42	2.9	56.9	56.8
C	5	0	-0.02	0.37	437	-0.05	-3.3	1.00	0.37	3.3	53.4	53.3
C	4	-2	-0.01	0.37	437	-0.03	-1.7	1.00	0.37	2.6	53.4	53.3
C	3	-6	0.02	0.36	437	0.06	3.6	0.99	0.36	7.0	52.6	52.2
C	2	-3	0.02	0.40	437	0.05	3.2	1.00	0.40	4.4	55.4	55.3
C	1	-9	0.02	0.36	437	0.06	3.6	0.99	0.36	9.7	52.6	51.8
F	7	-7	-0.05	0.55	440	-0.09	-5.5	1.00	0.55	8.9	65.3	64.5
F	6	-3	-0.04	0.53	440	-0.08	-4.6	1.00	0.53	5.5	64.1	63.8
F	5	-6	-0.06	0.50	441	-0.12	-7.2	1.00	0.50	9.4	62.4	61.5
F	4	-1	-0.03	0.59	443	-0.05	-3.1	1.00	0.59	3.3	67.7	67.6
F	3	-8	-0.03	0.66	441	-0.05	-2.8	1.00	0.66	8.5	71.5	70.7
F	2	-10	0.00	0.60	442	0.00	0.0	1.00	0.60	10.0	68.1	67.1
F	1	-9	0.07	0.52	445	0.13	8.9	0.99	0.52	12.6	63.4	61.9
E	7	-10	0.00	0.52	441	0.00	0.0	1.00	0.52	10.0	63.4	62.4
E	6	-5	0.01	0.52	442	0.02	1.2	1.00	0.52	5.1	63.4	63.2
E	5	-7	0.02	0.54	442	0.04	2.4	1.00	0.54	7.4	64.6	64.1
E	4	-3	0.00	0.55	441	0.00	0.0	1.00	0.55	3.0	65.2	65.1
E	3	-9	0.00	0.53	441	0.00	0.0	1.00	0.53	9.0	64.0	63.2
E	2	-10	0.00	0.53	441	0.00	0.0	1.00	0.53	10.0	64.0	63.0
E	1	0	0.02	0.55	440	0.04	2.3	1.00	0.55	2.3	65.1	65.1
D	7	1	0.00	0.49	440	0.00	0.0	1.00	0.49	1.0	61.5	61.5
D	6	-2	0.02	0.45	438	0.04	2.8	1.00	0.45	3.5	58.8	58.7
D	5	0	0.02	0.42	437	0.05	3.1	1.00	0.42	3.1	56.8	56.7
D	4	0	0.01	0.39	437	0.03	1.6	1.00	0.39	1.6	54.8	54.7
D	3	0	0.00	0.36	437	0.00	0.0	1.00	0.36	0.0	52.6	52.6
D	2	-3	-0.01	0.30	437	-0.03	-2.1	1.00	0.30	3.6	48.1	48.0
D	1	2	0.00	0.25	437	0.00	0.0	1.00	0.25	2.0	43.9	43.8

RESULTS

Yaw Angle:	4.4 degrees	Stack Temperature:	439 F
Pitch Angle:	-1.0 degrees	Velocity*:	60.18 fps (feet per sec.)
Resultant Angle:	5.9 degrees	Axial Velocity:	59.71 fps
Standard Deviation:	4.0 degrees		

*velocity in the direction of flow

CARNOT
15991 Red Hill Ave., Suite 110
Tustin, California 92680
714-259-9520
FAX 714-259-0372

STRATIFICATION CHECK

Client: UCOS COLMAC
Project #: 1409-40985
Unit No: 2
Date: 6/28/94

Point	O_2 pt	Ref O_2	% Diff	Point	O_2 pt	Ref O_2	% Diff
F5	7.0	7.0	0.0%	C5	6.5	6.4	-1.6%
F4	6.4	6.5	1.5%	C4	6.6	6.6	0.0%
F3	7.3	7.4	1.4%	C3	6.5	6.6	1.5%
F2	7.0	7.0	0.0%	C2	6.4	6.4	0.0%
F1	6.7	6.7	0.0%	C1	7.4	7.5	1.3%
E5	6.5	6.5	0.0%	B5	6.0	6.1	1.6%
E4	6.7	6.8	1.5%	B4	6.2	6.3	1.6%
E3	7.1	7.1	0.0%	B3	6.5	6.6	1.5%
E2	6.9	7.0	1.4%	B2	6.7	6.8	1.5%
E1	6.7	6.8	1.5%	B1	6.6	6.7	1.5%
D5	6.9	7.0	1.4%	A5	7.1	7.3	2.7%
D4	6.3	6.4	1.6%	A4	6.7	6.9	2.9%
D3	7.2	7.2	0.0%	A3	7.4	7.5	1.3%
D2	7.7	7.7	0.0%	A2	6.7	6.8	1.5%
D1	7.0	7.0	0.0%	A1	6.4	6.6	3.0%

O2 Stratification= 1.0%

CARNOT
15991 Red Hill Ave. Suite 110
Tustin, California 92680
714-259-9520
FAX 714-259-0372

APPENDIX E

STRIP CHARTS












B4
B5
A2
A5


A5
A7
A4
A5
MOVED TO UNIT
0 10 20 30 40 50 60 70 80 90 100


MOVED TO U-1
A1
A2
A3
A4
A5
B1







THIS IS THE LAST PAGE OF THIS DOCUMENT

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. David Wonderly
Title: Client Project Manager
Region: Western
E-Mail: DWonderly@montrose-env.com
Phone: (714) 279-6777

Name: Mr. Matt McCune
Title: Regional Vice President
Region: Western
E-Mail: MMccune@montrose-env.com
Phone: (714) 279-6777